

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 04/01/2017
Issued in compliance with Order in Cases 15-E-0751 and 15-E-0082 dated 03/09/2017

Leaf: 249.0.1
Revision: 0
Superseding Revision:

GENERAL RULES

24. Service Classification Riders (Available on Request) – Continued

RIDER R - Net Metering for Customer-Generators - Continued

E. Metering

1. The Company will employ net energy metering to measure and charge for the net energy supplied by the Company. If the Customer is billed under demand rates, the Company will select a metering configuration that enables it to credit the Customer for the kWhr supplied to the Company by the Customer and measure the peak kW delivered by the Company to the Customer.
2. Interval metering with telecommunications capability is required for electric generating equipment placed in service after March 9, 2017, for the following: demand-billed accounts with on-site generation, demand-billed and energy-only RNM Host Accounts, and demand-billed and energy-only CDG Host Accounts. If interval metering is not required for billing under the Customer's Service Classification, the Customer shall be responsible for the installation of the meter upgrade at the cost described in General Rule 17.6 and shall provide and maintain the communications service pursuant to General Rule 6.5.
3. As provided in General Rule 7.1, the Customer shall furnish, install, and maintain all meter equipment (except meters and metering transformers) and meter wiring. The Company will install the metering necessary to obtain the data required to credit the Customer for the kWhr supplied to the Company.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY