

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 02/01/2017
Issued in compliance with Order in Cases 16-E-0060 and 16-E-0196 dated 1/25/2017

Leaf: 162.1
Revision: 0
Superseding Revision:

GENERAL RULES

20. Standby Service - Continued

20.3 Customers Exempt from Standby Service Rates - Continued

20.3.3 Customers With Targeted Exemptions

- (a) A Customer who newly installs or expands an efficient CHP generation facility on or after January 1, 2017, may apply for an exemption from Standby Service rates provided that all of the conditions specified below and in General Rule 20.3.4 are met:
- (i) the CHP facility has an aggregated capacity of 1 MW or greater and serves no more than the Customer's maximum potential demand;
 - (ii) the CHP facility has an average annual efficiency of 60 percent or greater and has a usable thermal energy component that absorbs a minimum of 20 percent of the CHP facility's total usage annual energy output;
 - (iii) the CHP facility is designed to meet NO_x emissions ratings specified in General Rule 20.3.4; provided, however, that the facility is designed to have maximum NO_x emissions of 1.6 lbs/MWh in zip codes not listed in that General Rule;
 - (iv) the Customer submits a completed application for interconnection in accordance with the SIR by December 31, 2019, and commences operation of the CHP by December 31, 2021, for either a new CHP facility or for the portion of an existing facility that is newly expanding; and
 - (v) if application is made to expand an existing CHP facility, only the facility's new portion that has an aggregated capacity of 1 MW or over is eligible under this provision, and it must be separately metered and billed.

Each eligible Customer will be exempt from Standby Service rates for the specified number of years from the date the CHP commences operation, as shown below. Such Customer will also receive shadow billing, for informational purposes, at the pilot rate established in Case 16-E-0060, during the pilot term, and at the then-effective Standby Service rates thereafter, unless the Customer makes a one-time election to be switched to billing under either the pilot rate or the then-effective Standby Service rates:

<u>Number of Years Exempt</u>	<u>Average Annual Efficiency</u>
4	60% or greater but less than 63%
7	63% or greater but less than 65%
10	63% or greater and peak efficiency of 65% or greater

For purposes of measuring the above, the annual overall efficiency and peak efficiency will be determined using the Higher Heating Value of the fuel input. For peak efficiency, power island system efficiency will be measured at the prime mover connections for fuel and electricity, and at the heat recovery device connections for steam and/or hot water. Peak efficiency calculations assume full utilization of electrical and thermal energy.

Applications made under General Rule 20.3.3(a) shall not exceed 50 MW of new or expanded Efficient CHP, of which at least 25 MW of aggregated CHP capacity shall be for Customers who take both standby service and service under SC 11, where the SC 11 Contract Demand is greater than zero. If Customers served under this General Rule switch to the pilot rate established in Case 16-E-0060, the MW will not be available for re-use under this General Rule.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY