

PSC NO: 10 – Electricity
 Consolidated Edison Company of New York, Inc.
 Initial Effective Date: 03/01/2017
 Issued in compliance with order in Case 16-E-0560 dated 01/25/2017

Leaf: 247
 Revision: 4
 Superseding Revision: 3

GENERAL RULES

24. Service Classification Riders (Available on Request) – Continued

RIDER R – Net Metering for Customer-Generators – Continued

D. Requirements for Parallel Operation

Electric generating equipment may be operated in parallel with the Con Edison system under this Rider under the following conditions:

1. The generating equipment must be designed, installed, interconnected, tested, and operated in accordance with applicable government, industry, and Company standards and must comply with the standards contained in the Standardized Interconnection Requirements.
2. The Company may install a dedicated transformer or transformers or other equipment if necessary to protect the safety or adequacy of electric service provided to other Customers. Upon the written request of the Customer, the Company will furnish within 45 days a written explanation for the Company's decision to install a dedicated transformer or other equipment. A Customer taking service under this Rider shall pay for the cost of installing such transformer or other equipment to protect the safety or adequacy of electric service provided to other Customers only up to a maximum amount, inclusive of taxes, as follows:

| Electric Generating Equipment | Total Rated Capacity | Maximum Amount |
|---|----------------------------|-------------------------|
| Residential micro-CHP | 1 to 10 kW | \$350 |
| Residential fuel cells | up to 10 kW | \$350 |
| Residential micro-hydro | up to 25 kW | \$350 |
| Solar | up to 25 kW | \$350 |
| Wind | up to 25 kW | \$750 |
| Farm waste at Farm Operation | up to 2,000 kW | \$5,000 |
| Farm wind | above 25 kW up to 500 kW | \$5,000 |
| Nonresidential solar or wind | above 25 kW up to 2,000 kW | Company's actual cost* |
| Non-residential fuel cells | up to 2,000 kW | Company's actual cost * |
| Non-residential micro-hydro | up to 2,000 kW | Company's actual cost * |
| Non-residential farm waste at Non-farm Location | up to 2,000 kW | Company's actual cost* |

*Actual cost applies unless otherwise specified in the SIR.

The Customer will not unreasonably refuse the Company's request to install a dedicated transformer on the Customer's premises and will cooperate with the Company to facilitate such installation in a cost effective manner. If a dedicated transformer cannot be installed in a cost effective manner or if the dedicated transformer(s) or other equipment does not satisfactorily ameliorate the concerns prompting its installation, the Customer is responsible to implement such additional measures as required to satisfactorily ameliorate the concerns as a condition for continued service under this Rider.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY