

PSC NO: 1 ELECTRICITY
COMPANY: VILLAGE OF FAIRPORT
INITIAL EFFECTIVE DATE: 03/01/2012

LEAF: 13
REVISION: 1
SUPERSEDING REVISION: 0

SERVICE CLASSIFICATION NO. 4 (CONT'D)

possible, equal currents in each of the three phase conductors at the point of taking. If at any time the current in any phase conductor shall exceed the average of the currents in all the three phase conductors by more than five percent (5%) the amount to be paid by the customer for the period within which the unbalance occurred, shall be increased by a percentage equal to that of the unbalance.

- (f) The customer shall maintain a power factor at the point of delivery of not less than 90% lagging or leading as measured on a 30 minute basis. If the customer is notified that their power factor has fallen below 90%, corrective action must be taken within ninety (90) days. If the customer fails to take corrective action within the ninety (90) days after notification, the Municipal Commission shall discontinue service under Service Classification #4 and bill service under Service Classification #3 until power factor is corrected.

Issued by: Kenneth W. Moore, Village Administrator, Fairport, N.Y