

PSC NO: 15 ELECTRICITY
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION
INITIAL EFFECTIVE DATE: 01/01/12

LEAF: 163.5.22
REVISION: 0
SUPERSEDING REVISION:

38. NET METERING FOR CUSTOMER GENERATORS (Cont'd)

E. Residential, Farm Service and Non-Residential Wind Electric Generation

Applicability:

Applicable to Service Classification Nos. 1, 2, 3, 6 and 13.

Customers that own or operate wind electric generating equipment, as defined in Public Service Law Section 66-l, with a rated capacity of not more than 25 kW for residential wind generation, a rated capacity of not more than 500 kW for farm service wind generation where the customer's primary residence is located on the same land used for such farm service, and a rated capacity of not more than 2,000 kW for non-residential wind generation, may supply their electric load and/or sell electric energy to the Company as set forth in General Information Section 3.C. Total wind electric generation load on Central Hudson's system may not exceed 3.6 MW.

The customer shall be responsible for payment of one-half the expense of the interconnection on wind electric generating equipment with a rated capacity of more than 25 kW. Customers with wind electric generating equipment will be required to pay Central Hudson's actual costs of installation for a dedicated transformer(s) or other equipment, should it be determined to be necessary for safety and adequacy of service, up to a maximum of: (a) \$750 in the case of a residential, farm, or non-residential customers with wind electric generating equipment with a combined rated capacity of not more than 25kW and; (b) \$5,000 in the case of a farm service customer with wind electric generating equipment with a combined rated capacity of not more than 500kW. Such costs for a non-residential customer with wind electric generating equipment with a combined rated capacity greater than 25kW, and no greater than 2MW, will be pursuant to Addendum New York State Standardized Interconnection Requirements.

In the event that the total rated generating capacity of wind electric generating equipment that provides electricity to the Company through the same local feeder line exceeds twenty percent of the rated capacity of the local feeder line, the customer owning or operating such equipment may be required to comply with additional measures to ensure the safety of the local feeder line. Wiring and switches of these facilities may be arranged in parallel so as to permit the flow of current from the customer to the Company and vice versa.

Issued by: Michael L. Mosher, Vice President, Poughkeepsie, New York