0

PSC NO: 10 – Electricity Consolidated Edison Company of New York, Inc. Initial Effective Date: 11/01/2011

63 Leaf: Revision: Superseding Revision:

GENERAL RULES

6. Meters – Continued

6.7 Seals on Meters and Other Equipment

All meters (regardless of ownership), meter equipment and other enclosures on the service side of the meter must be sealed and/or locked. No person, except a duly authorized employee of the Company or the Customer's Meter Service Provider, shall be permitted to break or replace a seal or to alter or change a meter or its connections or location; except that, when wiring changes are being made by the Customer following receipt of Company specifications as to service supply, a qualified electrician may break the meter seal and remove and remount a meter when authorized to do so by the Company or the Customer's Meter Service Provider.

6.8 Testing of Meters

At such times as the Company may deem proper, or as the Public Service Commission may require, the Company will test Customer-owned meters and its meters and measuring devices in accordance with the standards and bases prescribed by the Public Service Commission. The Company may, but is not required to, test meters furnished by Meter Service Providers.

6.9 Unmetered Service

Where the Customer's only utilization equipment consists of warning lights, electric signs or the like, having a total rated capacity of less than 10 kW and an estimated use of less than 3,000 kWhr per month and such equipment has a definitely determinable demand, and is operated on a fixed schedule, the Company may supply unmetered service at the applicable Service Classification rates and charges, upon the basis of the usage determined by the Company and endorsed upon the agreement for service. Unmetered service will not be supplied at any location where the Customer is supplied with metered service or to any account taking Standby Service. The Company reserves the right at any time to meter service previously supplied on an unmetered basis.