

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 11/01/2011

Leaf: 405
Revision: 0
Superseding Revision:

**SERVICE CLASSIFICATION NO. 5
ELECTRIC TRACTION SYSTEMS**

Applicable to Use of Service for

Light, heat, and power for electric traction purposes and miscellaneous uses in connection with the operation of a railroad or rapid transit system, where the Customer's requirements are in excess of 10 kilowatts, subject to the Common Provision and Special Provisions of this Service Classification.

Character of Service

Of the various characteristics of service listed and more fully described in General Rule 4, the following may be designated for service by the Company under this Service Classification, subject to the limitations set forth in such Rule. Frequencies and voltages shown are approximate. All are continuous.

Standard Service

Any derivative of the standard alternating current, 3 phase, 4 wire system at 60 cycles and 120/208 volts.

Non-Standard Service

Low Tension Alternating Current - 60 cycles:

- Single phase at 120/240 volts
- Three phase at 265/460 volts
- Three phase at 240 volts
- Two phase at 120/240 or 230 or 240 volts

High Tension Alternating Current - 60 cycles:

- Three phase at 2,400/4,150 volts
- Three phase at 13,200 or 26,400 or 33,000 volts
- Three phase at 69,000 volts
- Three phase at 138,000 volts

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY