

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 11/01/2011

Leaf: 478
Revision: 0
Superseding Revision:

SERVICE CLASIFICATION NO. 12
MULTIPLE DWELLING SPACE HEATING

Applicable to Use of Service for

Light, heat, and power used in a multiple dwelling in which the entire space heating requirements of the residential tenants are supplied by the use of electricity purchased from the Company subject to the Common Provisions and Special Provisions of this Service Classification.

Character of Service

Of the various characteristics of service listed and more fully described in General Rule 4, the following may be designated for service by the Company under this Service Classification, subject to the limitations set forth in such Rule. Frequencies and voltages shown are approximate. All are continuous.

Standard Service

Any derivative of the standard alternating current, 3 phase, 4 wire system at 60 cycles and 120/208 volts.

Non-Standard Service

Low Tension Alternating Current - 60 cycles:

- Single phase at 120/240 volts
- Three phase at 240 volts
- Two phase at 120/240 or 230 or 240 volts
- Three phase at 265/460 volts

High Tension Alternating Current - 60 cycles:

- Three phase at 2,400/4,150 volts
- Three phase at 13,200 volts
- Three phase at 26,400 volts
- Three phase at 33,000 volts
- Three phase at 69,000 volts
- Three phase at 138,000 volts

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY