

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 11/01/2011

Leaf: 245  
Revision: 0  
Superseding Revision:

## GENERAL RULES

### 24. Service Classification Riders (Available on Request) – Continued

#### RIDER R - Net Metering for Customer-Generators - Continued

##### A. Applicability - Continued

Service will be provided under this Rider to eligible Customers on a first come, first served basis based on the date the Company notifies the Customer that it has received a complete project application in accordance with the Standardized Interconnection Requirements. The Company reserves the right to limit service under this Rider to solar electric generating equipment, farm waste electric generating equipment, micro-CHP generating equipment, and fuel cell electric generating equipment having a total rated generating capacity of 110,820 kW and to wind electric generating equipment having a total rated generating capacity of 33,246 kW. The Company's decision to provide service above either or both of these capacity limits shall not constitute a waiver of the Company's right to thereafter stop taking applications for service under this Rider.

The Company will perform a detailed, site-specific study when it receives a request for interconnection to its distribution network system (distributed and spot networks). Inverter-based solar generators up to 200 kW may interconnect to the Company's distribution network system without such a study if the generating equipment has a rated capacity that does not exceed the peak load delivered to the Customer's premises as measured over the prior 24-month period. The Company reserves the right to decline requests from generators to interconnect to the distribution network system when the Company deems it necessary to protect its system, facilities, or other Customers.

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY