

P.S.C. NO. 3 ELECTRICITY**ORANGE AND ROCKLAND UTILITIES, INC.**

INITIAL EFFECTIVE DATE: April 1, 2012

SUPERSEDING REVISION:

LEAF: 117

REVISION: 1

0

Issued in compliance with Order in Case 10-E-0362 dated 03/20/2012.

GENERAL INFORMATION**9. INTERCONNECTION OF NON-COMPANY GENERATING EQUIPMENT (Continued)****9.1 GENERATORS OPERATED IN PARALLEL WITH THE COMPANY'S DISTRIBUTION SYSTEM**
(Continued)

- (B) The following provisions are applicable to customers with private generating facilities on their premises not connected directly to transmission facilities that (i) commenced operation prior to February 1, 2000; or (ii) commenced operation between February 1, 2000 and December 30, 2004, and either have a total nameplate rating between 301 kVA and 2 MW or between 401 kW and 2 MW in the case of Farm Waste Generators or are connected to a network system; or (iii) have a total nameplate rating greater than 2 MW and are connected in parallel with the distribution system:
- (1) Such facilities shall abide by the Company's "Operating, Metering, and Equipment Protection Requirements for Parallel Operation of Generating Facilities" appropriate for the nameplate rating of the customer's generator; and
 - (2) The customer shall notify the Company of all changes in customer's generating equipment prior to making such changes and shall allow the Company's representatives access to those facilities at all reasonable times.

Customers connecting to transmission facilities shall be subject to interconnection requirements imposed by the NYISO.

(C) Residential Small Electric Solar, Micro-Combined Heat and Power ("Micro-CHP"), Micro-Hydroelectric ("Micro-Hydro"), and Fuel Cell Electric Generators

Any residential customer taking service under Service Classification No. 1 or 19 and operating a qualifying (1) solar electric generator with a generating capacity of 25 kW or less, (2) Micro-CHP generator with a rated capacity of at least 1 kW and not more than 10 kW, (3) Micro-Hydro generator with a rated capacity of not more than 25 kW, or (4) fuel cell generator with a rated capacity of not more than 10 kW; located and used at the customer's residence in compliance with the provisions of Section 66-j of the New York State Public Service Law, is eligible for interconnection and net metering in accordance with Rider N.

Issued By: William Longhi, President, Pearl River, New York