

PSC NO: 214 ELECTRICITY
NIAGARA MOHAWK POWER CORPORATION
INITIAL EFFECTIVE DATE: NOVEMBER 16, 2009

LEAF: 58
REVISION: 3
SUPERSEDING REVISION: 2

SERVICE CLASSIFICATION NO. 3

APPLICABLE TO USE OF SERVICE FOR:

Unmetered electric service to customer owned or leased outdoor lighting luminaires located along streets, highways, roadways and ways open to public use where Company has facilities appropriate for service for the State of New York, for municipal corporations for duly constituted street lighting districts, and for duly constituted public agencies, public authorities and public corporations.

CHARACTER OF SERVICE:

Electric lighting service supplied unmetered shall be for customer owned, customer maintained outdoor lighting equipment at approximately 60 Hertz and at appropriate voltages and currents designated by Company. The Company provides no maintenance to customer owned street lighting equipment under this service classification. Customer shall inquire as to the characteristics of the service to be supplied prior to the purchase of electrical equipment. Customer owned street lighting equipment will meet Company specifications and approval. Company may restrict the type of equipment customer requests to install.

Customer may designate the following types of service.

A. Overhead Service (OH)

Service is available only in those areas where an overhead distribution system at the appropriate service voltage is maintained by the Company. Existing Company poles may be available for customer owned street lighting equipment. Pole attachment fees for the use of Company wood poles are applicable. Additional Company facilities for secondary service will be installed by Company at customer's expense.

B. Underground Service (UG)

Service is available only in those areas where a distribution system at the appropriate service voltage is maintained by the Company. The customer will be required to construct facilities to a handhole or transformer facility of Company's distribution system. If customer desires an underground service from an appropriate existing overhead distribution system, customer will be required to construct such facilities to an appropriate Company overhead pole with sufficient cable to reach Company's secondary wiring. The riser cable shall be installed in customer owned conduit attached to Company's pole in accordance with Company's specifications.

APPLICATION FOR SERVICE:

The customer is required to execute a completed Form "P" - Application for Service by a duly authorized representative, to which a designated Schedule "W" shall be attached. The Schedule "W" will list the lamp types, sizes and quantities initially supplied. Such application and attached schedule, when accepted by Company, shall constitute an agreement between customer and Company, subject to the terms and conditions set forth in this service classification. Attachment of customer equipment to Company distribution poles requires an additional customer agreement for pole attachments.

Issued by Thomas B. King, President, Syracuse, NY