

PSC NO: 1 GAS

LEAF: 210.42

COMPANY: KEYSpan GAS EAST CORPORATION

REVISION: 0

INITIAL EFFECTIVE DATE: 11/03/06

SUPERSEDING REVISION:

STAMPS:

Form of Facilities Construction and Reimbursement Agreement
For Electric Generation
EXHIBIT B – Continued

VI. Above Ground Pipe Requirements

- a. All piping that will be above grade must be of low temperature material. Pipe and fittings must meet Charpy V-Notch values of 20 ft-lbs @ 0 F.
- b. Pipe materials shall be: for 2 1/2" through 10": ASTM 333 Grade 6, standard wall; for pipe 12" and larger: API 5L X-42 PSL-2 standard wall.

VII. Records

- a. A copy of all Certified Material Test reports for all pipe, fittings and welding rods must be provided to KeySpan before gassing in.
- b. A professional engineer stamped letter shall be submitted to KeySpan which identifies that the gas piping has been designed, tested, and installed to all applicable codes and standards.
- c. A copy of the as-built mechanical drawings from outlet of meter to inlet of compressor building shall be provided.

Issued by: Joseph F. Bodanza, Senior Vice President, Hicksville, NY