PSC NO: 90 GAS COMPANY: NEW YORK STATE ELECTRIC & GAS CORPORATION INITIAL EFFECTIVE DATE: 11/1/07

LEAF: 73.1 REVISION: 0 SUPERSEDING REVISION:

GENERAL INFORMATION

10. CONDITIONS OF GAS SERVICE: (CONT'D)

- (b) Contact dual-fuel customers and instruct them to switch to an alternate fuel (excluding plant protection.) These customers will be asked to maintain their incoming gas supplies which will be redirected to supply core customers.
- (c) Implement the New York Gas Group Standard Operating Procedure for the Pooling of Gas Supply and/or other mutual aid procedures if appropriate.
- (d) Issue public appeal for voluntary load reduction.
- (e) Request the County or Counties affected to declare a State of Emergency in order to close nonessential facilities.
- (f) Non-core requirements for customers with full facilities to burn an alternate fuel (in lieu of gas) and having annual requirements greater than 50,000 Dth/year. Curtailment shall be in order by size beginning with the largest customer.
- (g) Non-core requirements for customers with full facilities to burn an alternate fuel (in lieu of gas) and having annual requirements greater than 12,000 Dth/year. Curtailment to be in order by size beginning with the largest.
- (h) Curtail large industrial and commercial transportation customers that have returned to sales service and the Company was unable to obtain a pipeline capacity contract to serve them to the minimum level required to maintain building protections;
- (i) Industrial and commercial space heating boiler fuel requirements, air conditioning, electric generation, and other non-process purposes where the total base annual requirements are 12,000 Dth. or larger.
- (j) Curtail non-residential customers with annual requirements of 12,300 Dth. or larger, starting with the largest first, in accordance with the Gas Emergency Plan.

(i) In the event of non-compliance or if further curtailment is required, the Company may perform physical curtailment of the above customers.

- (k) Process requirements for which there are technically feasible alternative fuels, and industrial and commercial requirements for space heating (other than boiler fuel use), where the total base annual requirements are 12,000 Dth. or larger.
- Industrial and commercial space heating boiler fuel requirements, air conditioning, electric generation and other non-process purposes, where the total base annual requirements are between 1,200 Dth. and 11,999 Dth inclusive.
- (m) Process requirements for which there are technically feasible alternate fuels, and industrial and commercial requirements for space heating (other than boiler fuel use), where the total base annual requirements are between 1,200 Dth. and 11,999 Dth. inclusive.

Issued in compliance with order in Case 06-G-0059 dated August 23, 2007

Issued By: James A. Lahtinen, Vice President - Rates & Regulatory Economics, Binghamton, NY