

P.S.C. No. 1 – Water  
United Water Westchester Inc.  
Initial Effective Date: January 11, 2009

Leaf No. 26  
Revision: 0  
Superseding Revision: 0

- (b) The Customer making such application shall pay in advance to the Company the estimated cost of the complete installation of such street connection and when the installation is completed if the Actual cost is less than the estimate the Company shall refund to the Customer the difference between the actual cost and the amount deposited or if the actual cost is greater than the amount deposited the customer shall pay to the Company such difference.
- (c) Whenever regular water service is begun through such connection the Company shall refund the entire cost of such street service connection with depreciation at the rate of five per cent (5%) per annum for the period such street service connection had been in the ground.

#### **11. STREET SERVICE CONNECTIONS IN PRIVATE STREETS:**

On and after the effective date hereof, rules and regulations relating to street service connections in private streets shall be the same as those governing street service connections in public streets. See Section 9 of the Schedule.

#### **12. ADVANCE STREET SERVICE CONNECTIONS IN PRIVATE STREETS:**

On and after the effective date hereof, rules and regulations governing advance street service connections in private streets shall be the same as those governing advance street service connections in public streets. See Section 10 of the Schedule.

#### **13. CUSTOMER'S SERVICE PIPES:**

- (a) The Customer's service pipe between the curb cock and the structures on the premises to be supplied shall be furnished and installed by the Customer at his expense and risk. The pipe shall be of a size no smaller than the street service pipe and the minimum size shall be three-quarter (3/4") inch. The pipe shall be of ample strength to withstand the water pressure at the point where located and may be of red brass, copper, lead, cement lined cast iron or such other kind of pipe as will conform to the reasonable requirements of the Company in furnishing adequate and safe service.
- (b) All Customers' service pipes hereafter shall be laid to provide a cover equal to that of the street service connection but in no case shall the cover be less than (4') feet. The service pipe shall be placed on firm and continuous earth so as to give unyielding and permanent support, and shall be installed in a trench at least two feet in a horizontal direction from any other trench wherein are laid gas pipe, sewer pipe or other facilities, public or private, unless otherwise specifically authorized and approved by the Company.

Issued by: M.J. Pointing, V.P. and General Mgr., 2525 Palmer Ave., New Rochelle, NY 10801