

P.S.C. No. 1 – Water
United Water Westchester Inc.
Initial Effective Date: January 11, 2009

Leaf No. 28
Revision: 0
Superseding Revision: 0

- (d) When the Customer's meter is not installed in a building it shall be placed in a meter box or vault of a type approved by the Company and furnished at the expense of the Customer, which box or vault, shall be placed just inside the Customer's property line or at such other location as may be approved by the Company.
- (e) Each premise shall be supplied through a separate meter or meters.
- (f) Meters will be maintained by the Company at its expense in so far as ordinary wear is concerned, but damage due to hot water, freezing, or other external causes arising out of or caused by the Customer's negligence or carelessness shall be paid for by the Customer.
- (g) The Customer shall properly notify the Company of any defect in or damage in the meter or its connections.

17. MULTIPLE METERS:

- (a) When a premise is supplied by a battery of meters the registration of such meters shall be combined and the proper minimum charge applied to each meter.
- (b) Where a premise is supplied through more than one service at the request of the Customer, then each meter shall be treated separately, the registration shall not be combined, and the proper minimum charge applied to each meter.

18. METER TESTS AND TEST FEES:

- (a) All meters are accurately tested before installation. Meters are also periodically tested in accordance with the Public Service Commission's regulations. The Company may at any time remove any meter for routine tests, repairs or replacement.
- (b) Any Customer may request the Company or Public Service Commission to make a special test of the accuracy of a meter which test will be made in accordance with the standard regulations of the Commission.
- (c) For such special test the fee as established herein shall be paid in advance by the complainant, but should the said meter be found upon said test to be more than four percent (4%) incorrect at any rate of flow within the "Normal test flow limits" to the prejudice of the Customer, the fee so paid shall be returned to the complainant and the meter shall forthwith be adjusted by the Company or another meter which has been properly adjusted shall be installed.

Issued by: M.J. Pointing, V.P. and General Mgr., 2525 Palmer Ave., New Rochelle, NY 10801