

PSC No. 1 - WATER
COMPANY: LONG ISLAND WATER CORPORATION d/b/a
LONG ISLAND AMERICAN WATER
INITIAL EFFECTIVE DATE: JULY 31, 2008

LEAF NO.: 52
REVISION: 0
SUPERSEDING REVISION: 0

GENERAL INFORMATION

- .3.4 If the customer discontinues service at any time prior to ten full seasons the Corporation will charge the adjusted deposit with the entire cost of such service less depreciation at the rate currently authorized by the Commission, for the period such service has been in the ground and return to the customer the difference remaining.
- .4 The Corporation will furnish and install the entire service from the main to the property line and will furnish and install a meter not to exceed 2" to record the quantity of water consumed.
- .4.1 The Corporation shall have the right to determine the size of the service line and the size of the meter.
- .5 The customer shall install and maintain a meter box or pit of substantial construction at or immediately adjacent to the property line, unless another location for good reason shown, is approved by the Corporation, and provide the necessary piping therein for the connection of the water meter.
- .5.1 The customer shall furnish and install in the meter box or pit an approved double check valve (DCV) or reduced pressure zone (RPZ) device and three resilient seat type valves in accordance with the layout furnished by the Corporation filed with the Public Service Commission of the State of New York in this section, Subsection F. The DCV or RPZ device shall be installed in accordance with the New York State Health Department guidelines regarding cross connection control and as described under the Extension of Facilities Section VI Subsection J in the General Information Section included herein.

C. Applicable to "Do It Yourself" type of Lawn Sprinkler Systems which is supplied by the existing service line for General Use (one service line – one meter).

- .1 Service Classification No. 1 – Season starts May 1 and ends November 1 annually.
- .2 This type of sprinkler service is connected to an outside hose bib or sill cock not in excess of ¾".
- .2.1 It is not usually installed by a licensed plumber.
- .3 The Corporation will not guarantee that the existing service line is adequate to furnish both the general and sprinkler service.

Issued by: William M. Varley, President, 733 Sunrise Highway, Lynbrook, NY