

**PSC No. 1 - WATER**  
**COMPANY: LONG ISLAND WATER CORPORATION d/b/a**  
**LONG ISLAND AMERICAN WATER**  
**INITIAL EFFECTIVE DATE: JULY 31, 2008**

**LEAF NO.: 36**  
**REVISION: 0**  
**SUPERSEDING REVISION: 0**

### **GENERAL INFORMATION**

of the actual cost incurred including, but not limited to the charge for repair of the condition and restoration of the service.

- .5 **Reconnection Charge**  
A charge will be made for reconnecting service which has been disconnected for nonpayment of bills or violation of the Corporation's rules, provided that the work of disconnecting has required only the removal of the Corporation's equipment from the customer's premises or turn off at the curb box. The service reconnection charge in such instances is as follows:  
\$50.00 during normal business hours (Monday through Friday);  
\$75.00 outside of normal business hours (Monday through Friday); and  
\$100.00 on weekends or holidays  
If a customer or his agent refuses to permit an authorized agent or employee of the Corporation to remove or disconnect the meter or turn off at the curb box because of nonpayment of bills or violation of the rules, or if a customer willfully restores service without permission of the Corporation, and it becomes necessary to disconnect the service at the Corporation's main, the charge for reconnecting service will be actual cost and expenses incurred by the Corporation incident to the disconnection and reconnection of the service. Any charge for reconnection, where service was disconnected for nonpayment of bills, or violation of the Corporation rules, is payable before service is restored.

### **VI - EXTENSION OF FACILITIES**

#### **A. Service Pipe Specifications**

- .1 Copper pipe or copper tubing of "K" wall thickness or equal and approved by the Corporation shall be laid, but shall not be less than ¾" in diameter. Where the main has a cover of less than (five) 5 feet, the service pipe shall have a cover at least equal to that of the main, and in no case shall the service pipe have a cover of less than 4 feet. Where, the service pipe must have less than 4 feet of cover in the opinion of the Corporation, because of ducts or other sub-surface conditions preventing the service being laid at this depth, it shall be sufficiently insulated against frost with a covering of suitable waterproof material. The installation shall be subject to the Corporation's inspection at the Corporation's expense.

Issued by: William M. Varley, President, 733 Sunrise Highway, Lynbrook, NY