

PSC NO: 119 ELECTRICITY
NEW YORK STATE ELECTRIC & GAS CORPORATION
Initial Effective Date: 09/01/03

Leaf: 113
Revision: 0
Superseding Revision:

GENERAL INFORMATION

9. Distributed Generation Interconnection Requirements (Cont'd.)
- F. I. Application Process for the Interconnection of New Distributed Generation Units of 300 kVA or Less, or Farm Waste Generators of 400 kW or Less, Connected to Radial Distribution Lines (Cont'd.)

B. APPLICATION PROCESS STEPS (Cont'd.)

STEP 9 - The Applicant's Facility is Tested in Accordance With the Standard Interconnection Requirements.

The verification testing will be performed in accordance with the written test procedure provided in STEP 5 and any site-specific requirements identified by NYSEG in STEP 6.

The final testing will be conducted at a mutually agreeable time, and NYSEG shall be given the opportunity to witness the tests. Single-phase inverter-based systems rated 15 kVA or less will be allowed to interconnect to the NYSEG system prior to the verification test for a period not to exceed two hours, for the sole purpose of assuring proper operation of the installed equipment.

STEP 10 - Interconnection.

The applicant's facility will be allowed to commence parallel operation upon satisfactory completion of the tests in STEP 9. In addition, the applicant must have complied with and must continue to comply with the contractual and technical requirements.

STEP 11 - Final Acceptance and Utility Cost Reconciliation

Within 60 days after interconnection, NYSEG will review the results of its on-site verification and issue to the applicant a formal letter of acceptance for interconnection. At this time, NYSEG will also reconcile its actual costs related to the applicant's project against the application fee and advance payments made by the applicant. The applicant will receive either a bill for any balance due or a reimbursement for overpayment as determined by the NYSEG's reconciliation, except that a net metering customer-generator may not be charged in excess of the costs of installing the dedicated transformer described above. The applicant may contest the reconciliation through the filing of a formal complaint with the Commission.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY