

PSC NO: 119 ELECTRICITY  
NEW YORK STATE ELECTRIC & GAS CORPORATION  
Initial Effective Date: 09/01/03

Leaf: 119  
Revision: 0  
Superseding Revision:

## GENERAL INFORMATION

### 9. Distributed Generation Interconnection Requirements (Cont'd.)

#### F. II. Interconnection Requirements for New Distributed Generators 300 kVA or Less, or Farm Waste Generators of 400 kW or Less, Connected to Radial Distribution Lines (Cont'd.)

##### B. Operating Requirements (Cont'd.)

- c. A hazardous condition is revealed by a NYSEG inspection;
- d. Protective device tampering
- e. Parallel operation prior to NYSEG approval to interconnect. (In the event that no disconnect has been provided as required in Section II.D, NYSEG shall disconnect the generation utilizing an alternate method. NYSEG shall make a reasonable attempt to assure that the generation is disconnected in a manner so as not to interrupt any on-site customer load.)

The disconnect switch may be opened by NYSEG for the following reasons, after notice to the responsible party has been delivered and a reasonable time to correct (consistent with the conditions) has elapsed:

- a. generator-owner has failed to make available records of verification tests and maintenance of its protective devices;
- b. A generator-owner's system interferes with NYSEG equipment or equipment belonging to other NYSEG customers;
- c. generator-owner's system is found to adversely affect the quality of service to adjoining customer(s).

NYSEG will provide a name and telephone number so that the customer can obtain information about the NYSEG lock-out. The customer shall be allowed to disconnect from NYSEG without prior notice in order to self-generate.

Following a generation facility disconnect as a result of the operation of a protective function trip sequence, the generation facility shall remain disconnected until NYSEG's service voltage and frequency has recovered to NYSEG's acceptable voltage and frequency limits for a minimum of five (5) minutes.

Under certain conditions, NYSEG may require direct transfer trip (DTT) (see Section IV: Glossary of Terms for definition). NYSEG shall provide detailed evidence as to the need for DTT.

If an applicant proposes any modification to the system that has an impact on the interface at the PCC after it has been installed and a contract between NYSEG and the customer has already been executed, then any such modifications must be reviewed and approved by the NYSEG before the modifications are made.

Issued by: James A. Lahtinen, Vice President – Rates & Regulatory Economics, Binghamton, NY