

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: August 25, 2003
Issued under the authority of the PSC in Case 03-E-0001 and Case 02-E-1282, order effective August 5, 2003

Leaf No. 163.1
Revision: 1
Superseding Revision: 0

SERVICE CLASSIFICATION NO. 1 (Cont'd)

RESIDENTIAL SERVICE

SPECIAL PROVISIONS: (Cont'd)

5. Net Metered Farm Waste Generator Service

- a. Service under this provision will be offered to customers who comply with the terms and conditions set forth in Rule 10 of this tariff.
- b. The farm waste generator must be fueled at a minimum of 90% on an annual basis by biogas produced from the anaerobic digestion of agricultural waste such as livestock manure materials, crop residues, and food processing waste, with a least 75% by weight of its feedstock being livestock manure materials on an annual basis.
- c. This service will be offered, on a first come, first serve basis, to a limited level of participation. The total of the rated generating capacity of all the farm waste generators in the Company's service area shall not exceed 0.4% of RG&E's 1996 total electric demand—5,220 kW.
- d. Interconnection costs charged by the Company for a dedicated transformer or transformers, should it be determined to be necessary, shall not exceed \$3000.
- e. In the event that the total rated generating capacity of electric generating equipment that provides electricity to the Company through the same local feeder line exceeds twenty percent of the rated capacity of the local feeder line, the customer owning or operating such equipment may be required to comply with additional measures to ensure the safety of the local feeder line.
- f. The Company will meter and bill all energy used and produced in accordance with the terms and conditions set forth in this tariff.
- g. In relation to the Customer's equipment or its own facilities, the Company may enter the Customer's premises without notice as necessary to maintain the reliability or safety of its own equipment, facilities, and services.
- h. The Company will install, if necessary, an appropriate meter for the Customer's service classification to measure the electricity delivered to the Customer and a separate non-demand, non-time differentiated meter to measure the electricity supplied to the Company's electric system by the Customer's generator.
- i. The Customer may elect to use a single meter with bi-directional capability. Customers are advised that the use of a standard meter, running in reverse, does not meet accuracy standards as documented under Public Service Law.
- j. On a monthly basis, electricity delivered to the Customer shall be netted with electricity supplied by the Customer. If the amount delivered to the Customer is greater than the amount supplied by the Customer, the Customer shall be billed at the appropriate rate for the net kilowatt-hours. If the amount supplied by the Customer is greater than the amount delivered to the Customer, the excess shall be applied to the next billing period. If, at the end of the year, there is a credit for electricity supplied to the Company by the Customer, the Company shall issue a cash payment to the Customer for the kilowatt-hour credit, priced at the Company's avoided cost.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York