

PSC No: 20 - Electricity  
Rochester Gas and Electric Corporation  
Initial Effective Date: June 1, 2003  
Issued under the authority of the PSC in Case 03-E-0634, order effective May 23, 2003

Leaf No. 132  
Revision: 1  
Superseding Revision: 0

### GENERAL INFORMATION

## 14. DISTRIBUTED GENERATION INTERCONNECTION REQUIREMENTS (Cont'd)

### B. Operating Requirements

The generator-owner shall provide a 24-hour telephone contact(s). This contact will be used by the utility to arrange access for repairs, inspection or emergencies. The utility will make such arrangements (except for emergencies) during normal business hours.

Voltage and frequency trip set point adjustments shall be accessible to service personnel only.

The generator-owner shall not supply power to the utility during any outages of the system that serves the PCC. The generator-owner's generation may be operated during such outages only with an open tie to the utility. Islanding will not be permitted. The generator-owner shall not energize a de-energized utility circuit for any reason.

The disconnect switch specified in Section II.D, Disconnect Switch, may be opened by the utility at any time for any of the following reasons:

- a. to eliminate conditions that constitute a potential hazard to utility personnel or the general public;
- b. pre-emergency or emergency conditions on the utility system;
- c. a hazardous condition is revealed by a utility inspection;
- d. protective device tampering;
- e. parallel operation prior to utility approval to interconnect.

The disconnect switch may be opened by the utility for the following reasons, after notice to the responsible party has been delivered and a reasonable time to correct (consistent with the conditions) has elapsed:

- a. A generator-owner has failed to make available records of verification tests and maintenance of its protective devices;
- b. A generator-owner's system interferes with utility equipment or equipment belonging to other utility customers;
- c. A generator-owner's system is found to adversely affect the quality of service to adjoining customers.

The utility will provide a name and telephone number so that the customer can obtain information about the utility lock-out. The customer shall be allowed to disconnect from the utility without prior notice in order to self generate.

Following a generation facility disconnect as a result of the operation of a protective function trip sequence, the generation facility shall remain disconnected until the utility's service voltage and frequency has recovered to the utility's acceptable voltage and frequency limits for a minimum of five (5) minutes.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York