

PSC No: 18 - Electricity  
Rochester Gas and Electric Corporation  
Initial Effective Date: June 1, 2003

Leaf No. 41  
Revision: 0  
Superseding Revision:

**SERVICE CLASSIFICATION NO. 2 (Cont'd)**  
**STREET LIGHTING SERVICE - CUSTOMER-OWNED EQUIPMENT**

**SPECIAL PROVISIONS: (Cont'd)**

order to accommodate such customer attachment, an existing pole must be replaced to comply with existing Company or industry standards, the customer shall, in addition to any rearrangement costs, pay the installed cost of the new pole, plus any removal costs, less the percentage depreciation applicable to the old pole and any salvage value.

- g. Have the right, but not the duty, to inspect and to discontinue service to any customer-owned equipment which in the opinion of the Company shall have become unsafe for further service for any cause beyond the Company's control, giving prompt notice thereof to customer.

2. The customer shall:

- a. Inquire of the Company as to the point(s) of service, character of service to be rendered and the acceptability of the type and location of equipment to be attached or connected to the Company's facilities, prior to installing street lighting facilities to be served under this Service Classification.

Customer shall install, or have installed, regulated or reactor ballasts with a power factor of not less than 85% and make, or have made, attachments and/or connections in accordance with the specifications of the National Electric Safety Code and Company specifications. Company specifications shall include the specifications of other joint users or prior licensees to the extent customer is advised thereof by Company. The Company or other joint user may restrict the type of equipment and bracket support to be installed on a wood pole.

- b. Be responsible for all engineering design, construction, mapping and maintenance of its facilities. Record keeping shall also be the responsibility of the customer.
- c. Upon initially requesting service, or additional service, submit a map or detailed drawing of the geographical area to be lighting showing the location, number, type, size, and burning hours of lamps to be installed. Within thirty days after completion of work, the customer shall submit an "as built" layout to be used by Company for billing purposes, recording service locations and transformer loading.

(Continued on next leaf)

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York