

PSC No: 19 - Electricity  
Rochester Gas and Electric Corporation  
Initial Effective Date: June 1, 2003

Leaf No. 54  
Revision: 0  
Superseding Revision:

### GENERAL INFORMATION

### 3. EXTENSION AND MAINTENANCE OF COMPANY FACILITIES TO SERVE CUSTOMER (Cont'd)

#### **F. TRANSFORMER VAULTS**

Whenever a transformer vault is necessary to supply a customer with alternating current service in the network district, the customer will provide space satisfactory to the Company in which space the Company will construct, at its expense, a transformer vault for housing its transformers and necessary switching equipment. These transformers may, if desired by the Company, be tied in with the Company's secondary distribution system.

Where a transformer vault already available or in service on the customer's premises is adequate for service in the judgment of the Company, and the customer requires a change in the location of the vault, such a change will only be made at the expense of the customer.

#### **G. STANDBY: AUXILIARY OR BREAKDOWN SERVICE**

Customers operating power generating equipment and having equipment that may be operated by privately generated power or by purchased power, may contract for service under an applicable Service Classification.

The customer shall not operate his own power generating equipment in parallel with the Company's service except under control by, and with the Company's consent.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Rochester, New York