

PSC NO. 3 GAS
St. Lawrence Gas Company, Inc.
Initial Effective Date: 06/04/2004

Leaf: 46
Revision: 0
Superseding Revision:

GENERAL INFORMATION

2. General Rules, Regulations, Terms and Conditions: (Cont'd)

III. Metering, Billing, Discontinuance of Service and Complaints: (Cont'd)

A. Metering and Billing: (Cont'd)

5. Fixed Factor Measurement (Cont'd)

At each installation where fixed factor measurement is used:

- a. The regulated delivery pressure to the customer's meter will be maintained under operating conditions at +/- one percent of the set pressure (absolute).
- b. Each regulator shall be sealed in a manner that would indicate any unauthorized tampering with the outlet pressure adjustment screw.
- c. All regulators and pressure compensating indexes used in fixed factor measurement shall be clearly identified.
- d. The company shall provide a means for verifying the outlet set pressure of the regulator initially and periodically thereafter.