

PSC No: 120 - Electricity
New York State Electric and Gas Corporation
Initial Effective Date: December 1, 2003

Leaf No. 79
Revision: 0
Superseding Revision:

GENERAL INFORMATION

16. General Retail Access: (Cont'd.)

E. ESCO/DC Participation: (Cont'd.)

2. ESCO or DC Requirements: (Cont'd.)

- (k) ESCOs and DCs must plan to meet the full Electric Power Supply requirements of the Eligible Customer. Electric Power Supply is defined as the electricity required to meet the Eligible Customer's needs, including energy, Energy Losses, Unforced Capacity, Unforced Capacity Losses, and Unforced Capacity Reserves. ESCOs/DCs must provide enough Electric Power Supply to cover Energy Losses, Unaccounted For Energy ("UFE"), and UCAP Losses associated with their load. The Loss and UFE factors are as set forth below.

Voltage <u>Level</u>	Service <u>Classification</u>	Energy Loss <u>Factor</u>	Capacity Loss <u>Factor</u>
Transmission	7-4	1.0000	1.0000
Subtransmission	3S, 7-3	1.0150	1.0200
Primary	3P, 7-2	1.0377	1.0480
Secondary	1, 2, 6, 7-1, 8, 9, 12, Outdoor/Street Lighting	1.0728	1.0738

In the event there is a material change or an anticipated substantial increase in the Electric Power Supply requirement of an Eligible Customer or Eligible Customers, ESCO or DC will notify NYSEG of such change prior to such change or increase according to the details set forth in the Supplier Manual, and will cooperate with NYSEG, as reasonably required by NYSEG, to accommodate such change or increase.

ISSUED BY: James A. Lahtinen, Vice President Rates and Regulatory Economics, Binghamton, New York