

PSC No. 1 - Water
United Water South County Water Inc.
Initial Effective Date: 06/01/05

Leaf No. 43
Revision: 0
Superseding Revision: 0

GENERAL INFORMATION

VI. SERVICE PIPE AND MAINS (cont'd.)

A. Separate Application for Each Premises (cont'd.)

- (2d) a building owned or leased by one customer having a number of apartments, offices, or lofts which are rented to tenants and using in common one hall and one or more means of entrance; or
- (2e) a building two or more stories high under one roof owned or leased by one customer having an individual entrance for the ground floor occupants and one for the occupants of the upper floors.

B. Service Pipe Materials

The entire service pipe shall be copper tubing or other pipe of strength and quality approved by the Company. The minimum diameter of the service pipe shall be ¾". For services two inches or larger in diameter, cast iron or other pipe of strength and quality approved by the Company shall be used.

C. Minimum Depth of Service Pipes

Minimum depth of service pipes from main to premises shall be four feet six inches below the surface of the ground. Where covering over mains is less than five feet, the connection shall be made on the side of the main and the service pipe shall in no case have less covering than the main.

D. Inspection of Service Pipe

That portion of the service pipe without the territorial limits of any street, avenue, road or way, or other public place, as hereinafter defined, which is installed by the customer at his or her expense, must be approved by the Company before the trench is backfilled.

VII. METERED SERVICE

A. Location of Meters

The customer shall provide a place acceptable to the Company for the location of the meter. The customer shall install, in a manner approved by the Company, the necessary piping, fittings, valves and pipe couplings to receive the water. The Company requires the installation of suitable equipment properly located and installed, to prevent back flow of hot water which may cause damage to the meter or other damage to the customer's plumbing.

Issued in compliance with order in Case 02-W-0949 dated 05/21/2004

Issued by: Robert J. Iacullo, President, 360 West Nyack Rd., West Nyack, NY 10994