

PSC No:4 Gas
Corning Natural Gas Corporation
Initial Effective Date: 3/30/2005

Leaf: 200
Revision: 1
Superseding Revision: 0

SERVICE CLASSIFICATION NO. 20
DISTRIBUTED GENERATION SERVICE - RESIDENTIAL

APPLICABLE TO USE OF SERVICE FOR:

Any Residential customer using distributed generation technologies including, but not limited to, microturbines, internal combustion engines and fuel cells. The distributed generation technologies must be installed and fully operable before taking service under this Service Classification. A separate meter does not need to be installed for this Service Classification.

CHARACTER OF SERVICE:

Customers Purchasing Gas Supply from an Alternate Supplier:

Delivery of customer-owned gas, pipeline quality, on a firm basis from a receipt point within the Company's service territory to which this schedule applies to the facilities at the customer's existing delivery point, as specified in the customer's Application for Firm Transportation Service. Customer-owned gas to be transported by the Company must have a minimum BTU value of 1,000 British Thermal Units per cubic foot on a dry basis. The gas quality must meet the Public Service Commission's rules and regulations regarding concentrations of hydrogen sulfide, total sulfur and ammonia. Filtration of dust and liquid hydrocarbons, and water removal will be required. Delivery pressure will be determined at the sole discretion of the Company but will not be less than four (4) inches, water column.

Customers Purchasing Gas Supply from Corning Natural Gas:

Continuous, natural gas or a mixture of natural gas and other gas of not less than 1,000 British Thermal Units per cubic foot on a dry basis. Delivery pressure will be determined at the sole discretion of the Company but will not be less than four (4) inches, water column. The Company reserves the right to reject any application for service under the Service Classification where, in the sole discretion of the Company, the provision of service would require the purchase of incremental capacity on the transmission system of its pipeline suppliers.

"Issued in Compliance with PSC Order dated August 4, 2004 in Case No. 02-M-0515"

Issued by Thomas K. Barry, Chairman, President & C.E.O., Corning, NY 14830