

..DID: 9356
..TXT: PSC NO: 3 WATER LEAF: 5
COMPANY: OCEAN BAY PARK WATER CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 10/01/99 SUPERSEDING REVISION:
STAMPS:
RECEIVED: 07/09/99 STATUS: Effective EFFECTIVE: 10/01/99

GENERAL INFORMATION

III. SERVICE PIPE AND MAINS (Continued)

5. A building two or more stories high under one roof owned or leased by one customer and having an individual entrance for the ground floor occupants and one for the occupants or the upper floor, or
6. A combination of buildings, such as a garden-type apartment, owned by one customer, in one common enclosure, none of the individual buildings of which is adapted to separate ownership, or
7. A public building, or
8. A single plot, such as a park or playground.

B. Service Pipe Materials

The entire service pipe shall be polyethylene tubing or other pipe of strength and quality approved by the Company. The minimum diameter of the service pipe shall be 3/4 inch. For services two inches or larger in diameter, cast iron or other pipe of strength and quality approved by the Company shall be used.

C. Intentionally left blank.

D. Inspection of Service Pipe

That portion of the service pipe outside the territorial limits of any street, avenue, road or way, or other public place as hereinafter defined (see VII, General Information, par. A) which is installed by the customer at his/her expense must be approved by the Company before the trench is backfilled. The Company will install and maintain the service line between the main and the meter pit.

Issued By: David Ash, Secretary, 42 Mermorial Plaza, Pleasantville, NY 10570-2913
(Name of Officer, Title, Address)