

..DID: 20319  
..TXT: PSC NO: 15 ELECTRICITY LEAF: 272  
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 1  
INITIAL EFFECTIVE DATE: 11/22/02 SUPERSEDING REVISION: 0  
STAMPS:  
Suspended by order in Case 02-E-1108. See suppl. No. 18  
RECEIVED: 08/22/02 STATUS: Effective EFFECTIVE: 03/22/03

SERVICE CLASSIFICATION NO. 14

STANDBY SERVICE

APPLICABLE TO USE OF SERVICE FOR:

All purposes, where for all or a portion of the Customer's electric power requirement is supplied from a generation facility which does not supply energy to the Customer by means of the Company's delivery facilities, and where the Customer elects to have the Company supply energy to the Customer by means of the Company's delivery facilities. For purposes of this Service Classification, "delivery facilities" shall mean any facilities or equipment that are part of the Company's electrical system regardless of the voltage level or functional classification.

With the exceptions listed below, Customers who decline service under this tariff are required to electrically isolate themselves from the Company's electric system and the Company will not be required to maintain or supply service to such customers. A Customer shall be considered electrically isolated if (a) the electrical points of contact where interconnection may occur are separated and least 100 feet from any other interconnected electrical service of such Customer, or (b) the disconnected isolated service is not within the same building or structure as any other interconnected electrical services of the Customer and not housed within a common enclosure with other interconnected breakers and/or fuses of the Customer.

STANDBY SERVICE IS NOT APPLICABLE TO:

Residential Photovoltaic Power Producing Facilities

Standby service rates shall not apply to residential retail customers with photovoltaic generating systems ten (10) kilowatts or less provided they comply with the Residential Photovoltaic Interconnection Standards set forth in the PV-Addendum of this rate schedule.

Emergency Generators

Standby service shall not apply to customers whose only generating units are emergency generators. For the purposes of this Service Classification, a generating unit must meet each of the following three criteria to be considered an emergency generator: 1)the emergency generator is not capable of being operated in parallel with the Company's delivery system, except for closed-transition transfer switching where the term "closed-transition transfer" is characterized as a momentary make-before-break switching sequence, 2)the emergency generator is used exclusively for purposes of supplying electrical

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York