

**..DID: 6534**  
**..TXT: PSC NO: 9 GAS LEAF: 38**  
**COMPANY: CONSOLIDATED EDISON COMPANY OF NEW YORK, INC. REVISION: 0**  
**INITIAL EFFECTIVE DATE: 03/01/99 SUPERSEDING REVISION:**  
**STAMPS:**  
**RECEIVED: 12/08/98 STATUS: Effective EFFECTIVE: 03/01/99**

**GENERAL INFORMATION - Continued**

**III. General Rules, Regulations, Terms and Conditions under Which Gas Service Will Be Supplied, Applicable to and Made a Part of All Agreements for Gas Service - Continued**

**3. Installation of Mains and Services - Continued**

**(G) Service Lines and Metering - Continued**

- (2) If a meter is located outside the building;
  - (a) the service line will be deemed to terminate at the outlet of the meter, if the piping continues into the structure above ground, and
  - (b) at the outside of the building foundation wall, if the piping returns underground before entering the structure.

**(H) Emergency Electric Generators:**

When a Customer requests gas service for the purpose of supplying an emergency electric generator for use only during an interruption of electricity service, and for testing purposes, the following conditions shall apply:

- (1) Only sufficient emergency electric generating capacity shall be installed to provide the minimum needs for safety and health; and
- (2) The Customer shall pay all costs associated with the installation including, if necessary, all costs for system reinforcement, mains and service lines.

**(I) Form of Application:**

For form of application for extension of gas main in excess of 100 feet or for connection thereto of an Additional Customer or a Successor Customer, see Leaf No. 210.0.

**(General Information - Continued on Leaf No. 39.0)**

**Issued By: Joan S. Freilich, Executive Vice President & Chief Financial Officer, 4 Irving Place, New York, N. Y. 10003**  
(Name of Officer, Title, Address)