

..DID: 2023
..TXT: PSC NO: 8 GAS LEAF: 119
COMPANY: NATIONAL FUEL GAS DISTRIBUTION CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 04/01/98 SUPERSEDING REVISION:
STAMPS:
RECEIVED: 01/05/98 STATUS: Effective EFFECTIVE: 04/01/98
GENERAL INFORMATION (Cont*d)

II. 26. CONTINUED

If the gas received by the Company hereunder fails to meet any of the applicable quality specifications at the point(s) of receipt, in addition to the remedies provided herein, the Company shall have the options (1) to continue to receive such gas; (2) to refuse to receive and transport all or any portion of such gas until Customer brings the gas in conformity with the specifications; or (3) to receive such gas and, at Customer's expense, to treat or otherwise process same so as to cause the gas to conform to the applicable quality specifications. If the gas delivered fails to meet the 1,000 BTU standard specified hereunder, the Company shall also have the option to retain sufficient additional volumes of gas to compensate for such deficiency.

4. For all gas delivered for Customer's account to the Company, the volumetric measurement base shall be one (1) cubic foot of gas at a pressure base of fourteen and seventy-three hundredths (14.73) pounds per square inch absolute and a temperature base of sixty (60) degrees Fahrenheit. The average absolute atmospheric (barometric) pressure shall be fourteen and four tenths (14.4) pounds per square inch. The flowing temperature shall be sixty (60) degrees Fahrenheit and may be adjusted to actual flowing conditions by the Company if deemed necessary by the Company. All said gas shall be measured by orifice or displacement type meter or any other approved measuring device of equal accuracy. Orifice meters shall be installed and operated, and gas volumes computed in accordance with Report No. 3 of the Gas Measurement Committee of the American Gas Association, including any revisions applying thereto.

In the case of orifice meters, Customer must arrange to have each meter chart changed each week and on the last day of each billing period, and forwarded within 48 hours after each change. Customer must arrange to have all displacement meters read each week and on the

Issued by P.C. Ackerman, President, 10 Lafayette Square, Buffalo NY 14203
(Name of Officer, Title, Address)