

..DID: 2747

..TXT: PSC NO: 1 ELECTRICITY LEAF: 89

COMPANY: NEW YORK MUNICIPAL POWER AGENCY REVISION: 0

INITIAL EFFECTIVE DATE: 05/01/98 SUPERSEDING REVISION:

STAMPS:

Cancelled by 1 Rev. Leaf No. 89 Effective 12/01/1998

RECEIVED: 03/27/98 STATUS: Cancelled EFFECTIVE: 05/01/98

GENERAL INFORMATION (CONT'D)

3. A non-residential customer who, at any time directly or indirectly prevents or hinders a duly authorized officer agent of the Utility from entering the building or location, or from making an inspection or examination, at any reasonable time, may be billed a \$100 penalty charge for each offense.

F. Change of Service Equipment

Any change in the location of service equipment, for the convenience of the customer, provided such change is approved by the Utility, may be made by the Utility at the expense of the owner or occupant of the premises, who shall reimburse the Utility for any costs incurred.

G. Motors

Individual motors whose capacity is five horsepower or more must be three phase except where such service is not available. Single phase motors whose capacity exceed one-half horsepower shall normally be served at 208 volts or more, but the customer should contact the Utility in advance to ascertain the applicable conditions. All motors must be of a type that do not require excessive starting current deemed unreasonable by the Utility or must be equipped with a suitable starting device. All motors should be equipped with suitable undervoltage tripping mechanisms to protect against sustained under-voltage or service interruption and to prevent automatic disconnection of equipment upon momentary voltage disturbances or interruptions. All polyphase motors should be equipped with suitable protection to prevent single phase operation, improper direction of rotation and excessive heating because of overcurrent operation. Customer should contact Utility in advance to ascertain the applicable conditions.

Issued by: New York Municipal Power Agency