

..DID: 5058
..TXT: PSC NO: 12 WATER LEAF: 22
COMPANY: NEW YORK WATER SERVICE CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 11/06/98 SUPERSEDING REVISION:
STAMPS:
Effective date postponed to 04/01/99. See Supplement No. 2, 1
RECEIVED: 08/27/98 STATUS: Effective EFFECTIVE: 04/01/99

GENERAL INFORMATION

7. Ownership

Title to a service pipe and service connection installed within the territorial limits of a public street as hereinbefore defined shall be vested in the Company. Such service pipe and connections shall at all times remain the sole property of the Company and shall not be trespassed upon nor interfered with in any respect. The curb stop may not be used by the customer for turning on or shutting off the water supply but is for the exclusive use of the Company.

Service pipe and connections installed at applicant's expense on a private street shall at all times remain the sole property of the applicant, in whom title thereto shall vest.

8. Maintenance and Replacement

The Company, at its expense, will maintain and, when necessary, replace any service pipe and service connections within the territorial limits of a public street, as hereinbefore defined.

The Company, at its expense, will maintain and, when necessary, replace any service pipe and service connections from the main to the approximate property line of a private street, as hereinbefore defined, where the Company heretofore has claimed ownership of said service pipe and service connections.

At the customer's expense, the Company will maintain and, when necessary, replace any service pipe and service connections from its main to the approximate property line of a private street, as hereinbefore defined, where title to said service pipe and service connections is vested in the customer.

9. Service on Applicant's Property

At his own expense, the applicant shall install and maintain the service pipe from the territorial limit of the street to the premises, and two valves, the first to be located just inside the building wall, and the second valve adjacent to and on the house side of the meter, permitting control of the water supply by the customer. On services requiring meters of one inch (1") size and under, the two valves shall be incorporated in a meter yoke. The meter yoke and valves shall be of a make and type approved by the Company. For this installation and maintenance thereof the customer shall employ a

Issued by: Vincent Bohn, Vice President-Utilities, New York, NY