

..DID: 3269

..TXT: PSC NO: 1 ELECTRICITY

LEAF: 11

COMPANY: VILLAGE OF GREENE

REVISION: 0

INITIAL EFFECTIVE DATE: 05/17/98

SUPERSEDING REVISION:

STAMPS:

EFFECTIVE under authority of PSC 98-E-0666 made 04/29/98

Cancelled by 1 Rev. Leaf No. 11 Effective 04/01/2001

RECEIVED: 04/17/98 STATUS: Cancelled EFFECTIVE: 05/01/98

SERVICE CLASSIFICATION NO. 3 (CONT ' D)

SPECIAL PROVISIONS:

- (A) Fluctuating loads- A customer taking service for the operation of welders, X-ray machines or any other equipment having a highly fluctuating or large instantaneous demand which causes undue voltage disturbances on the circuit from which service is taken, thereby interfering with the service taken by other customers, shall install or pay for the necessary corrective equipment to avoid such interference with service to others or, failing to do so, shall pay in addition to the charge for services:

\$.55 per month per KVA of the nameplate rating of such equipment.

- (B) Primary Service - Where a customer's load requires a transformer installation in excess of 500 KVA, primary service at 4,160 volts will be supplied and the customer will be required to furnish and maintain the necessary substation and purchase energy at such primary voltage.

Issued by: Suzanne A. Jones, Clerk-Treasurer, Village of Greene