

..DID: 11288
..TXT: PSC NO: 15 ELECTRICITY LEAF: 19.1
COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION REVISION: 0
INITIAL EFFECTIVE DATE: 02/01/00 SUPERSEDING REVISION:
STAMPS: Issued Under Authority of Order of PSC dated 12/31/99, Case 94-E-0952
Cancelled by 1 Rev. Leaf No. 19.1 Effective 12/29/2000
RECEIVED: 01/31/00 STATUS: Cancelled EFFECTIVE: 02/01/00

3. APPLICATION FOR SERVICE (cont'd)

C. Distributed Generation Interconnection Requirements

Applicable to any customer installing a Distributed Generation (DG) unit with a nameplate rating of 300 kVA or less, connected in parallel with Central Hudson's radial distribution system (radial feeder) pursuant to the State of New York Public Service Commission's Opinion and Order Adopting standard Interconnection Requirements for Distributed Generation Units, Opinion 99-13 in Case 94-E-0952, issued and effective December 31, 1999, as the same may be revised, modified, amended, clarified, supplemented or superseded. The New York State Standardized Interconnection requirements for new distributed generation units with a nameplate capacity of 300 kVA or less to be operated in parallel with the Company's system on radial distribution feeders established in Opinion 99-13 are referred to as the ("SIR").

These requirements are not applicable to a DG unit which is not connected to Central Hudson's distribution grid. Compliance with all other tariff provisions, applicable to the Customer is required.

A. Definitions - The terms used herein are defined as follows:

- (1) "Contract" is defined as the document contained within the Opinion and Order Adopting Standard Interconnection Requirements for Distributed Generation Units, Case 94-E-0952, issued and effective December 31, 1999, as the same may be revised, modified, amended, clarified, supplemented or superseded.
- (2) "Customer" is defined here as a new or existing customer of CHG&E taking service under any otherwise applicable Service Classification, who makes application to and enters into a Contract with CHG&E, to install a DG unit as defined above.
- (3) "Distributed Generation (DG)" is defined as a small generating facility, not including photovoltaics, with a nameplate rating of 300 kVA or less (aggregated on the customer side of the point of common coupling) connected in parallel with Central Hudson's radial distribution system (radial feeder).
- (4) "New" with regard to DG units, is defined as those units that are installed after the effective date of this tariff.
- (5) "Usage" is defined as energy consumed by the Customer, not otherwise provided by the DG unit, as measured by Central Hudson's meter installed at the Customer's premises.

Issued by: Arthur R. Upright, Senior Vice President, Poughkeepsie, New York