

P.S.C. NO. 3 ELECTRICITY**ORANGE AND ROCKLAND UTILITIES, INC.**

INITIAL EFFECTIVE DATE: May 1, 2022

LEAF: 252.3

REVISION: 2

SUPERSEDING REVISION: 0

Issued in compliance with Order in Case 21-E-0074 dated 4/14/2022.

GENERAL INFORMATION**24. STANDBY SERVICE AND STANDBY SERVICE RATES (Continued)****24.3 DETERMINATION OF DEMAND (Continued)****(1) Contract Demand (Continued)**

- (c) If the customer received service from the Company for on-site generation at the premises for at least the past 24 months, and interval metering registers electricity served by all sources, including the Company's system and the on-site generating equipment, the contract demand shall be the customer's maximum 15-minute integrated demand served by all sources during the past 24 months, subject to the adjustments set forth in (a) above. No amount will be added to the contract demand for customer's on-site generation capacity if the customer demonstrates that its generating equipment was not operating during the period of the customer's maximum 15-minute integrated demand. If the customer received service from the Company for on-site generation at the premises for at least the past 24 months, and interval metering did not measure electricity supplied by all sources, the contract demand shall be the sum of the customer's maximum 15-minute integrated demand during the most recent 24 months and the total nameplate rating of the generating equipment, subject to the adjustments set forth in (a) above.
- (d) If a Rate Choice Customer without a generating facility received service from the Company under another service classification for the past 24 months, the contract demand shall be the customer's monthly maximum demand during the most recent 24 months.
- (e) For a Rate Choice Customer without a generating facility who received service from the Company under another service classification for less than 24 months, the contract demand will be reasonably determined through the Company's engineering analyses of the customer's electrical equipment and diversity of load, premises to be served, and information supplied by the customer at the Company's request.

Issued By: Robert Sanchez, President, Pearl River, New York