

PSC NO: 10 – Electricity
Consolidated Edison Company of New York, Inc.
Initial Effective Date: 02/27/2022

Leaf: 79.4
Revision: 0
Superseding Revision:

GENERAL RULES

8. Customer Use of Generating Equipment – Continued

8.4 Interconnection and Operation - Continued

8.4.1 – Continued

(B) – Continued

- (4) Where the Customer operates in parallel, the Customer shall provide and maintain on its premises all necessary facilities, as specified by the Company, for connecting the Company's feeder cables to the Customer's generating station, including transformers, circuit breakers, and all equipment and facilities necessary and required for synchronizing the Customer's generating plant with the Company's system and for controlling the flow of energy and wattless current and for protection of the interconnected systems. Such required facilities may include a communication system between the Customer's generating plant and the Company's system or district operator consisting of transmitting equipment and a communications path such as a leased telephone line or lines connecting these points to provide transfer trip of the Customer tie. Voice communication and telemetering of loads shall be provided at the Customer's expense.
- (5) The Customer is solely responsible for providing adequate protection for Customer's facilities operating in parallel with the Company's system. Except where caused by the Company's negligence, the Company will not be liable for, and the Customer shall indemnify and hold the Company harmless for, damages to the property of the Company or others or injuries to persons arising out of any occurrence related to the Customer's ownership, use or operation of the Customer's facilities.
- (6) For Standby Service: When a Customer who is a wholesale generator takes service through the same bus bar that it uses to export power to the wholesale grid, the station power when the generator is operating will be treated as if the generator were self-supplying from the load side of the meter.

For Buy-back service: The Customer shall provide suitable equipment, including indicating and recording instruments and telemetering, required by the Company for the proper operation and monitoring of the interconnection. The Customer's authorized representative in charge of the operation of the Customer's generating plant shall cause readings of the aforesaid meters to be taken at such intervals as may be required by the Company. The Customer will maintain a log record of such readings as part of the log records of the Customer's generating plant. Such logs will be made available for Company inspection and review at the Company's request.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY

Suspended to 06/27/2022 by order in Case 22-E-0064. See Supplement No. 75. The supplement filing date was 02/17/2022.
Suspended to 12/27/2022 by order in Case 22-E-0064. See Supplement No. 76. The supplement filing date was 06/09/2022.
Suspended to 04/26/2023 by order in Case 22-E-0064. See Supplement No. 77. The supplement filing date was 12/14/2022.
Suspended to 07/25/2023 by order in Case 22-E-0064. See Supplement No. 78. The supplement filing date was 04/24/2023.
Cancelled by supplement No. 79 effective 07/24/2023