

PSC NO: 10 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 02/27/2022

Leaf: 79.3  
Revision: 0  
Superseding Revision:

## GENERAL RULES

### 8. Customer Use of Generating Equipment – Continued

#### 8.4 Interconnection and Operation - Continued

##### 8.4.1 – Continued

##### (B) – Continued

- (2) All requests for parallel operation will be reviewed on a case-by-case basis. Parallel operation will be permitted only if, and to the extent, such operation does not jeopardize the adequacy or reliability of service to the Company's other Customers. Failure of the Customer at any time to comply with the terms and conditions specified by the Company in order to permit parallel operation will result in the Customer forfeiting its right to operate in parallel with the Company's system. In the event a Customer forfeits its right to operate in parallel with the Company's system, the Customer will be required to bear the reasonable expense associated with disconnecting the Customer's private plant from the Company's system. Where there is a dispute between the Customer and the Company with respect to the standards and charges for interconnection, the Customer may apply to the Public Service Commission for a ruling in the matter.
- (3) The Customer's generating plant and the Company's system may be operated in parallel as required subject to the Customer's compliance with the Company's design requirements and operating rules and procedures. To accomplish such parallel operation in a safe, economical, and efficient manner, operating instructions shall be prepared by the Company, and adhered to by the authorized operating representatives of the Customer. Such operating instructions shall include, among other things, procedures for:
  - (a) Maintaining proper voltage and frequency and for putting into effect voltage changes as required from time to time;
  - (b) Phasing and synchronizing the Customer's generating plant and the Company's system;
  - (c) Taking feeders out of service for maintenance or during emergency conditions and restoring them to service thereafter; and
  - (d) Controlling the flow of real power and reactive power between the Customer's generating plant and the Company's system.

Where there is to be parallel operation, the Customer's authorized operating representatives shall receive the necessary training from the Company's authorized operating representatives in the Company's operating procedures before parallel operation is begun.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY

Suspended to 06/27/2022 by order in Case 22-E-0064. See Supplement No. 75. The supplement filing date was 02/17/2022.  
Suspended to 12/27/2022 by order in Case 22-E-0064. See Supplement No. 76. The supplement filing date was 06/09/2022.  
Suspended to 04/26/2023 by order in Case 22-E-0064. See Supplement No. 77. The supplement filing date was 12/14/2022.  
Suspended to 07/25/2023 by order in Case 22-E-0064. See Supplement No. 78. The supplement filing date was 04/24/2023.  
Cancelled by supplement No. 79 effective 07/24/2023