

PSC NO: 12 – Electricity  
Consolidated Edison Company of New York, Inc.  
Initial Effective Date: 06/01/2022

Leaf: 17.7  
Revision: 2  
Superseding Revision: 1

## PASNY DELIVERY SERVICE

### General Provisions – Continued

#### Net Metering and Value Stack Tariff for PASNY Customer-Generators - Continued

##### Requirements for Parallel Operation:

Electric generating equipment may be operated in parallel with the Con Edison system under this provision under the following conditions:

- (1) The generating equipment must be designed, installed, interconnected, tested, and operated in accordance with applicable government, industry, and Company standards and must comply with the standards contained in the SIR.
- (2) The Company may install a dedicated transformer or transformers or other equipment if necessary to protect the safety or adequacy of electric service provided to other Customers. Upon the written request of the PASNY Customer, the Company will furnish within 45 days a written explanation for the Company's decision to install a dedicated transformer or other equipment. A PASNY Customer taking service under this provision shall pay for the cost of installing such transformer or other equipment to protect the safety or adequacy of electric service provided to other Customers only up to a maximum amount, inclusive of taxes, as follows:

<b>Electric Generating Equipment</b>	<b>Total Rated Capacity</b>	<b>Maximum Amount</b>
Solar	up to 25 kW	\$350
Wind	up to 25 kW	\$750
Farm waste at Farm Operation	up to 5,000 kW	\$5,000
Farm wind	above 25 kW up to 500 kW	\$5,000
Non-residential solar or wind	above 25 kW up to 5,000 kW	Company's actual cost*
Non-residential fuel cells	up to 5,000 kW	Company's actual cost *
Non-residential micro-hydro	up to 5,000 kW	Company's actual cost *
Non-residential farm waste at non-farm Location	up to 5,000 kW	Company's actual cost*
All other Electric Generating Equipment and Rated Capacities Served Under this General Provision		Company's actual cost*

\*Actual cost applies unless otherwise specified in the SIR.

The PASNY Customer will not unreasonably refuse the Company's request to install a dedicated transformer on the PASNY Customer's premises and will cooperate with the Company to facilitate such installation in a cost effective manner. If a dedicated transformer cannot be installed in a cost effective manner or if the dedicated transformer(s) or other equipment does not satisfactorily ameliorate the concerns prompting its installation, the PASNY Customer is responsible to implement such additional measures as required to satisfactorily ameliorate the concerns as a condition for continued service under this provision.