

P.S.C. No. 7 Electricity  
PENNSYLVANIA ELECTRIC COMPANY  
Initial Effective Date: 10/06/2019

Leaf: 34  
Revision: 0  
Superseding Revision:

#### Rule 7 - Extension of Company Facilities to Serve Customer (continued)

elapsed from the time of final approval of the subdivision or section thereof and less than twenty-five percent (25%) of the lots have been sold in the subdivision and every section thereof, except where ten percent (10%) or more of the lots in the subdivision or any section thereof have been sold within the last two (2) years. In cases where overhead installation would be permissible in accordance with condition (iii) above except that less than five (5) years have elapsed and the Company has reason to believe that the subdivision shall not be developed sufficiently soon to permit the orderly utilization of underground lines installed to serve the initial Applicant, the Company may petition the Commission to allow overhead installation.

If the Company receives an application for underground service and the estimated per foot cost of installation for the subdivision is greater than two (2) times the charge per foot filed with the Commission, the Company or Applicant may petition the Commission to allow overhead service.

The connection from the existing electric distribution system to the underground distribution lines installed within the Applicant's subdivision shall be made by the Company. The Company shall install underground without contribution from the Applicant an amount of supply circuit from the boundary line of the subdivision equal to one-hundred (100) feet per dwelling unit or up to one-hundred (100) feet of underground line times the average number of dwelling units per floor for multiple occupancy buildings without contribution by the Applicant.

Where any part of such connection in excess of the footage requirements of this Rule is to be placed overhead, Applicant must submit a written application to the Company at least seventy-five (75) days prior to the projected commencement of the construction of the supply line, and the Company must report such projected construction to the Commission for its approval no later than forty-five (45) days before such construction is commenced. The Commission reserves the right to require the underground installation of particular lines.

Whenever the Company intends to place any underground connecting supply lines between an existing distribution system and the underground distribution lines installed within an Applicant's subdivision, it shall inform the telephone company serving the area in which the subdivision is located.