

P.S.C. No. 7 Electricity
PENNSYLVANIA ELECTRIC COMPANY
Initial Effective Date: 10/06/2019

Leaf: 43
Revision: 0
Superseding Revision:

Rule 10 - Wiring, Apparatus and Inspection (continued)

Applicant/Customer Obligations

Electric service installations shall be in accordance with the National Electrical Code, and all applicable local, state and federal codes, statutes and regulations, except as modified by the Company's then-applicable handbooks, booklets or other documents covering such installations, as may be amended by the Company from time to time. A copy of the Company's requirements for electric service installations shall be provided to an Applicant/Customer upon request.

In the event that the Company is required by any state, federal or local governmental or public authority to place or relocate all or any portion of its facilities (including, but not limited to,) mains, wires or services, poles or underground feeders, the Applicant/Customer shall, without cost or expense to the Company, change the location of the Applicant's/Customer's point of delivery to a point specified by the Company.

Upon the Company designating a point of delivery at which its service line shall terminate, the Applicant/Customer shall provide, at its sole cost and expense, a place suitable to the Company for the installation of metering and all other electric facilities needed for the supply of electric energy by the Company or an ESCO. Meters shall be located on the outside of a building as near as possible to the service entrance or under certain circumstances, when approved by the Company, inside of a building.

The Company may refuse to connect with any Applicant's / Customer's installation or to make additions or alterations to the Company's service connection when such installation is not in accordance with the National Electrical Code, and all applicable local, state and federal codes, statutes and regulations, and where a certificate approving such installations, additions or alterations has not been issued by (i) an electrical inspection authority contained on a list of such authorities maintained by the Company and updated from time to time or (ii) any city or county inspection entity having exclusive authority to make electrical inspections in that area.

When a Customer's use of equipment having operating characteristics which impose high instantaneous demand such as, but not limited to, welders, hoists, electric furnaces and x-ray equipment, adversely affects or has the potential to adversely affect, in the Company's sole judgment, the Company's electric system, the Customer shall install at its