P.S.C. No: 1 – Water SUEZ Water New York Inc. Initial Effective Date: April 3, 2019 Leaf No. 20

Revision: 1

Superseding Revision: 0

GENERAL INFORMATION

3.5 Pipes on Customer's Premises

The entire pipe shall be copper tubing or other pipe of strength and quality approved in advance by the Company. The minimum diameter of the pipe shall be 3/4-inch. For services two inches or larger in diameter, ductile iron or other pipe of strength and quality approved by the Company shall be used.

3.6 Minimum Depth of Service Pipes

Minimum depth of service pipes from mains to premises shall be four feet six inches below the finished surface of the ground. Where covering over mains is less than five feet, the connection shall be made on the side of the main, and the service pipe shall in no case have less covering than the main. The curb box shall be set on a level with the finished grade of the ground or sidewalk and as near to the property line as practical.

3.7 Connecting Pipe

A. That portion of the pipe without the territorial limits of any street, avenue, road or way, as hereinbefore defined, which is installed by the Customer at his expense, shall be subject to the approval of the Company before the trench is backfilled.

B. No attachment to such pipe or any branch thereof shall be made between the meter and the main.

C. The Customer's service pipe shall be placed on firm and continuous earth so as to give unyielding and permanent support, and shall be installed in a trench at least two feet in a horizontal direction from any other trench wherein are laid gas pipe, sewer pipe or other facilities, public or private, unless otherwise specifically authorized and approved by the Company.

D. The Company may refuse to permit an Applicant to connect to its service pipe, unless the connecting pipe and other plumbing are in accordance with the plumbing and sanitary rules of the municipality and the Rules and Regulations of the Company.

E. Any repairs or maintenance necessary on the Customer's service pipe or any pipe or fixture in or upon the Customer's premises shall be performed by the Customer at his expense and risk.

F. The Customer shall notify the Company promptly of any leak, defect or damage affecting the service pipe between the property line and the point where metered.

Cancelled by supplement No. 7 effective 08/01/2020