

P.S.C. No. 2 – Water
SUEZ Water New York Inc.
Initial Effective Date: August 1, 2020

Leaf No. 32
Revision: 0
Superseding Revision:

definite periods or to prohibit it entirely. In this event, every effort will be made to notify Customers in advance by public notice.

8.3 Quality of Water

The Company does not undertake to supply any uniform quality of water for special purposes, such as manufacturing or processing plants, laboratories, swimming pools, bleaching or dyeing plants, or laundries. Customers requiring water of special quality, or water free from discoloration at all times, are required to provide their own means of treating the water, or provide such other protection as may be deemed necessary for the purposes required.

8.4 Liability of Company

Except as to the liability, if any, imposed by law, the Company will not be liable for any injury, casualty or damage resulting in any way from the supply or use of water service or from the presence or operation of the Company's structures, equipment, pipes, appliances or devices on the customer's premises, or from the use of any equipment or materials installed in conformity with the Company's requirements or recommendations.

8.5 Adequacy of Customer's Facilities

Neither by inspection nor non-rejection, nor in any other way, does the Company give any warranty, expressed or implied, as to the adequacy, safety or characteristics of any structures, equipment, pipes, appliances or devices owned, installed or maintained by the Customer, or leased by the Customer from third parties.

8.6 Cross Connection Control

The following provisions are intended to implement the Company's general right to protect its water supply from contamination and, more specifically, to implement the cross connection control responsibilities imposed on the Company by the Public Health Law and the State Sanitary Code. A cross connection means a physical connection through which a water supply could be contaminated via the intrusion of a contaminant from the Customer's premises as a result of backflow.

Backflow is a reversal in the normal or intended flow of water because of a differential in pressure that causes the flow of water into the distribution system from any source other than its intended source.

A. Upon determination of the Company or the State Commissioner of Health or, when duly authorized, a local Health Department, that a potential for contamination exists and that a backflow prevention device is required by provisions then in force under the State Sanitary Code or under guidelines issued by the State Commissioner of Health in force at such time, such device will be provided by and installed at the expense of the Customer. The State Sanitary Code essentially provides that, in such event, the Customer shall submit plans prepared by a professional engineer (or architect) licenses and registered in New York State. Such plans are to be approved by the State Health Department after approval by the Company. The State Sanitary Code also provides that the

Cancelled by supplement No. 6 effective 01/23/2023