

PSC No: 19 - Electricity
Rochester Gas and Electric Corporation
Initial Effective Date: April 7, 2021
Issued in compliance with Order in Case Nos. 19-E-0566 and 20-E-0543, dated March 18, 2021.

Leaf No. 120
Revision: 9
Superseding Revision: 8

10. DISTRIBUTED ENERGY RESOURCE (DER) INTERCONNECTION REQUIREMENTS

Applicable to any customer installing a Distributed Energy Resource (DER) unit (e.g. distributed generator or energy storage system) 5 MW or less, connected in parallel with the Company's utility distribution system.

These requirements are not applicable to a DER unit which is not connected to the Company's distribution grid. Compliance with all other tariff provisions applicable to the Customer is required.

A. Definitions

The terms are defined as the New York State Standard Interconnection Requirements and Application Process for New Distributed Generators and Energy Storage System 5 MW or Less Connected in Parallel with Utility Distribution Systems, as the same may be revised, modified, amended, clarified, supplemented or superseded, as posted on the NY PSC website at www.dps.ny.gov/distgen.htm, and as set forth within Addendum-SIR of this Schedule.

The Standardized Interconnection Requirements (SIR), including the standard applications and contracts, are set forth within the Addendum-SIR to this Schedule.

B. Queue Management

1. Applications submitted to the Company shall be subject to the Queue Management process as set forth within Addendum-SIR, Section II, J.