

PSC NO. 4 GAS
ORANGE AND ROCKLAND UTILITIES, INC.
 INITIAL EFFECTIVE DATE: August 1, 2017

LEAF: 90.3
 REVISION: 2
 SUPERSEDING REVISION:

GENERAL INFORMATION

13. FORM OF APPLICATION FOR SERVICE (Cont'd.)

13.4 Application for Non-Residential Service (New/Upgrade)

MULTIPLE (GANG) METER INSTALLATIONS

If you are installing more than 2 electric and/or gas meters at a single location, you are required to certify the following:

- The electric and/or gas installation shall be completed in accordance with applicable National Electric Code, National Fuel Gas Code and O&R's Specifications for Electric and Gas Installations.
- All electric meter pans and/or gas meter bars shall be labeled with the same designation used on the electric meter pan.
- The electric sub-panel serving the unit shall be labeled with the same designation used on the electric meter pan.
- Your electrical and plumbing contractors shall "ring out" each meter pan and/or fuel line to ensure that these main lines serve the specific units labeled on each meter pan and/or fuel line.
- You will assume liability for all installation work performed by your electrical and plumbing contractor.
- You understand and agree that noncompliance with these requirements and certifications shall result in delays in project completion and you may incur additional charges from O&R for additional inspections and administration.

Note: Copies of our Electric and Gas Specifications Manuals are available upon request at your local New Business Office.

Construction Near Electric Lines

The High-Voltage Proximity Act imposes certain obligations on any individual or company who may be working near electric utility power lines. Before you commence work on a project, you are required to notify your local utility. Paragraph 5 of §202-h states "Whenever any activity is to be performed requiring precautionary action under the Act, the employer, contractor or other person responsible for the activity shall promptly notify the owner or person in charge of the high-voltage line of the intended activity., such notification to be submitted at least five normal work days before the activity is to be performed. The owner or person responsible for the high-voltage line shall perform all necessary precautionary actions, and the employer, contractor or other person responsible for the activity shall be responsible for all costs of such precautionary actions. Under no circumstances shall activities requiring precautionary actions be undertaken before such precautionary actions have been completed. "

The Act also requires, but is not limited to the following:

- Educate workers of the inherent dangers in working near high-voltage lines;
- All high-voltage lines shall be considered energized until assurance has been given that they have been de-energized and grounded at the work site;
- Warning signs should be posted near high-voltage lines with the following language: "Danger Unlawful to Operate Any Part of This Equipment within 20-Feet of High-Voltage Lines."

By adhering to the Act, you protect the safety of your employees and the public. If you fail to comply with the requirements under the Act, you could be subject to certain fines and penalties.

Buildings of Public Assembly

Buildings of Public Assembly are buildings that normally admit the public and have capacity for 75 or more people. This would include, but is not limited to, schools, hospitals, nursing homes, licensed day care centers, churches, restaurants, theatres, department stores, factories, etc. (Office and Apartment buildings are excluded unless they have a community/meeting room, auditorium or cafeteria that can accommodate 75 or more people).

Does your facility meet this definition? ☐ Yes ☐ No

To Be Completed by Religious Groups, Community Residences & Veteran Organizations:

Public Service Law, Section 76, permits any corporation or association organized and conducted in good faith for religious purposes, certain community residences and veteran's organizations to receive service at rates no greater than the rates charged to residential customers.

Note: for electric service, in most cases the residential rate classification will be the most beneficial rate for you. O&R will assist you in making this determination based on the projected electric usage information you provide. It should also be noted that in certain instances your estimated use of demand in conjunction with the reported hours of operation may also provide substantial savings under O&R's primary metered rate classification.

Issued By: Timothy Cawley, President, Pearl River, New York
 (Name of Officer, Title, Address)