

P.S.C. NO. 3 ELECTRICITY
ORANGE AND ROCKLAND UTILITIES, INC.
INITIAL EFFECTIVE DATE: July 1, 2017

LEAF: 195
REVISION: 1
SUPERSEDING REVISION: 0

GENERAL INFORMATION

14. FORM OF APPLICATION FOR SERVICE (Continued)

14.2 APPLICATION FOR UNDERGROUND SERVICE - RESIDENTIAL SUBDIVISION (Continued)

NOTE: Under certain conditions, O&R will conduct an initial inspection of the installation to verify compliance with its specifications for electrical installations. If the installation is not in compliance with the Company's specifications, service shall not be rendered and the Company shall assess a re-inspection fee for any subsequent re-inspections of the installation.

Please consult your local O&R New Business Services Representative for additional codes and specifications.

Gas Service Requirements

The following provides basic information for the installation of gas services and meters. (Please consult your local O&R New Business Representative for additional information).

Gas services: All services must be installed in compliance with O&R's Natural Gas Installation Standards Handbook, which can be found on our website www.oru.com.

- Electric service must be installed in trench.
- Clean backfill must be available.
- Final grade must be marked on foundation.
- Each foundation must be marked with the Lot, Unit or Building Number to facilitate location information for our field personnel.
- The fuel line must be installed.
- If installed, conduit for gas services must be approved by O&R.

Gas Meters:

- Any appliance must be installed in conformance with the latest edition of the National Fuel Gas Code and O&R's Natural Gas Standards Handbook.
- On multi-unit construction where the gas meters are in a gang (more than one) configuration, the fuel lines must be permanently marked with the appropriate 911 address.
- Access to the unit must be available to our Service Department.
- The primary heating unit must be ready to accept service.

Note: Under certain conditions O&R will conduct an initial inspection of the installation to verify compliance with its specifications for gas installations. If the installation is not in compliance with the Company's specifications, O&R will not initiate service and the Company may assess as re-inspection fees of the installation.

MULTIPLE (GANG) METER INSTALLATIONS

If you are installing more than two electric and/or gas meters at a single location, you are required to certify the following:

- The electric and/or gas installation shall be completed in accordance with applicable National Electric Code, National Fuel Gas Code and O&R's Specifications for Electric and Gas Installations.
- All electric meter pans and/or gas meter bars shall be labeled with the same designation used on the electric meter pan.
- The electric sub-panel serving the unit shall be labeled with the same designation used on the electric meter pan.
- Your electrical and plumbing contractors shall "ring out" each meter pan and/or fuel line to ensure that these main lines serve the specific units labeled on each meter pan and/or fuel line.
- You shall assume liability for all installation work performed by your electrical and plumbing contractor.
- You understand and agree that noncompliance with these requirements and certifications shall result in delays in initiation of service and you may incur additional charges from O&R for additional inspections and administration.

Issued By: Timothy Cawley, President, Pearl River, New York