

P.S.C. NO. 3 ELECTRICITY**ORANGE AND ROCKLAND UTILITIES, INC.**

INITIAL EFFECTIVE DATE: April 1, 2018

Issued in compliance with Order in Case 15-E-0751 dated 2/22/2018.

LEAF: 119

REVISION: 2

SUPERSEDING REVISION: 1

GENERAL INFORMATION**9. INTERCONNECTION OF NON-COMPANY GENERATING EQUIPMENT (Continued)****9.1 GENERATORS OPERATED IN PARALLEL WITH THE COMPANY'S DISTRIBUTION SYSTEM**
(Continued)**(F) Wind Electric Generating Equipment (Continued)**

Any non-residential customer taking service under Service Classification Nos. 2, 3, 9, 20, 21, or 22 who owns or operates wind electric generating equipment, which includes one or more wind generators, located and used at the customer's premises with a total rated capacity of not more than 2 MW is eligible for interconnection and net metering in accordance with Rider N. Such generators with a rated capacity of greater than 2 MW and not more than 5 MW are also eligible for interconnection and the Value Stack Tariff in accordance with Rider N.

- (G) Interconnection applications submitted under the SIR will be subject to the Queue Management Plan contained in Attachment A of the Commission's January 25, 2017 Order in Case No. 16-E-0560.

9.2 GENERATORS OPERATED SEPARATELY FROM THE COMPANY'S DISTRIBUTION SYSTEM

A customer planning to install generating equipment that does not operate in parallel with the Company's system shall submit to the Company, prior to installation, equipment specifications which demonstrate that the customer's generating equipment cannot be operated in parallel with the Company's system.

Issued By: Robert Sanchez, President, Pearl River, New York