Received: 01/31/2019 Status: CANCELLED Effective Date: 01/30/2020

PSC NO: 10 – Electricity

Consolidated Edison Company of New York, Inc.

Initial Effective Date: 03/02/2019

Leaf: 31

Revision: 1

Superseding Revision: 0

## **GENERAL RULES**

## 4. Characteristics of Service – Continued

## 4.6 High Tension Service

- 4.6.1 Service of the following characteristics will be supplied only when warranted by the magnitude or location of the load or other physical conditions:
  - Three phase, 60 cycle service at 2,400/4,150 volts
  - Three phase, 60 cycle service at 13,200 volts
  - Three phase, 60 cycle service at 26,400 volts
  - Three phase, 60 cycle service at 33,000 volts
  - Three phase, 60 cycle service at 69,000 volts
  - Three phase, 60 cycle service at 138,000 volts

Service of the following characteristics is available only at premises now being supplied with such service and only to the extent of the capacity of the Company's existing service facilities (service conductors, feeders, and substation equipment):

- Three phase, 60 cycle service at 3,000 or 7,800 volts
- Three phase, 60 cycle service at 6,900 volts
- Two phase, 60 cycle service at 1,950 volts
- Single phase or three phase, 60 cycle service at 2,400 volts

High tension service may be designated by the Company for service when warranted by the magnitude or location of the load, or other physical conditions, or when it would result in the least cost to the Company.

High tension service will not be supplied to Customers for whom the Company designates secondary service from the Company's secondary mains.

Whenever a primary feeder that supplies a high tension Customer is out of service, the high tension Customer is responsible for isolating its high tension equipment from the out of service feeder. During a high electric load period, a high tension Customer must isolate its high tension equipment as soon as possible, but no later than six hours after receiving notification from the Company. If the high tension Customer does not isolate its equipment within six hours, Con Edison may engage a contractor to isolate the Customer's high tension equipment and the Customer must provide all required access to its equipment. The Customer will be responsible for reimbursing Con Edison for all costs associated with the contractor performing the isolation.

Issued by: Robert N. Hoglund, Senior Vice President & Chief Financial Officer, New York, NY

Cancelled by supplement No. 66 effective 01/23/2020 Suspended to 01/30/2020 by order in Case 19-E-0065. See Supplement No. 65. The supplement filing date was 12/18/2019 Suspended to 12/30/2019 by order in Case 19-E-0065. See Supplement No. 62. The supplement filing date was 06/18/2019 Suspended to 06/30/2019 by order in Case 19-E-0065. See Supplement No. 61. The supplement filing date was 02/13/2019