Received: 11/14/2018 Status: CANCELLED Effective Date: 12/01/2018

PSC NO: 15 ELECTRICITY

COMPANY: CENTRAL HUDSON GAS & ELECTRIC CORPORATION
INITIAL EFFECTIVE DATE: 12/1/2018

LEAF: 272.1

REVISION: 5

SUPERSEDING REVISION: 4

Issued in Compliance with Order in Case 15-E-0751 et al. dated September 12, 2018

## SERVICE CLASSIFICATION NO. 14 (Cont'd)

STANDBY SERVICE (Cont'd)

## STANDBY SERVICE IS NOT APPLICABLE TO: (Cont'd)

## Technologies Eligible Under Public Service Law ("PSL") §66-j and §66-l:

Standby service rates shall not apply to customers owning or operating electric generating equipment as defined in PSL §66-j and §66-l, up to the system size limits contained in General Information Section 48.B, when such customers are taking service under the provisions of General Information Section 37, 38, 46 or 48 and comply with the Standardized Interconnection Requirements set forth in the SIR-Addendum of this Rate Schedule.

## **Emergency Generators**

Standby service shall not apply to customers whose only generating units are emergency generators. For the purposes of this Service Classification, a generating unit must be designated in the customer's Application for Electric Standby Service with the Company as an emergency generator and must meet each of the following requirements to be considered an emergency generator:

- 1) the emergency generator is not capable of being operated in parallel with the Company's delivery system, except for closed-transition transfer switching where the term "closed-transition transfer" is characterized as a momentary make-before-break switching sequence, and
- 2) the emergency generator is used exclusively for purposes of supplying electrical power to the customer when electrical power is not available from the Company, and
- 3) no load is served by the emergency generator while electric service is available from the Company to the premises, except for regularly scheduled tests when the generator is required to operate under load or for NYISO Emergency Response Programs or for NYISO unforced capacity requirements for special case resources, and

Issued by: Anthony S. Campagiorni, Vice President, Poughkeepsie, New York