Received: 11/14/2018 Status: CANCELLED Effective Date: 12/01/2018

PSC NO: 10 – Electricity

Leaf: 244.1

Consolidated Edison Company of New York, Inc.

Revision: 0

Initial Effective Date: 12/01/2018 Superseding Revision:

Issued in compliance with Order in Cases 15-E-0751 and 15-E-0082 dated 09/12/2018

## **GENERAL RULES**

## 24. Service Classification Riders (Available on Request) - Continued

## RIDER R - Net Metering and Value Stack Tariff for Customer-Generators - Continued

Applicable to SCs 1, 2, 5, 8, 9, 11, 12, and 13

## A. Applicability - Continued

The kW of facilities with generating equipment located near each other will be aggregated to determine if the kW limit is met unless each facility meets all of the following criteria: (a) each is located on a separate site (i.e., a separately deeded location); (b) each is separately metered and interconnected to the Company's grid; and (c) each is operated independently of the others. The aggregated rated capacity of electric generating equipment shall be limited to 25 kW for residential Customers served under Grandfathered Net Metering or Phase One NEM, 2,000 kW for non-residential Customers served under Grandfathered Net Metering or Phase One NEM, and 5,000 kW for Customers served under the Value Stack Tariff. The Company will waive the 2,000 kW limit for a Grandfathered Net Metering or Phase One NEM Customer whose solar electric generating facility successfully participated in the NYSERDA – Competitive Solar PV Solicitation: Program Opportunity Notice ("PON") 2589, PON 2860, or PON 2956 or the New York City Department of Environmental Protection and Economic Development Corporation's March 2, 2012 Request for Proposals ("RFP") if the Customer demonstrates that the PON or RFP participant made good faith efforts to comply with the 2,000 kW limit in configuring its proposal.

Issued by: Robert Hoglund, Senior Vice President & Chief Financial Officer, New York, NY